



CA-NV AWWA Water Loss Technical Assistance Program

Wave 4 Water Audit Level 1 Validation Document

Water System Name: City of Huntington Park

Water System ID Number: 1910049

Water Audit Period: Calendar 2016

Water Audit & Water Loss Improvement Steps:

Steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated water audit:

Registered for Water Loss Conference meters. Initiated large meter change out program; researching feasibility of meter replacement policy. Upgrade SCADA system to effectively manage water system operation. System integration in progress. Discussing feasibility and procedure for a random meter testing policy. Attended all Wave training. Began collecting data on production well annual calibration testing. Survey City facilities for installation of water

Certification Statement by Utility Executive:

in their manual, Water Audits and Lass Control Programs, Manual M36, Fourth Edition and in the Free Water Audit Software version 5. Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water

Edgar P. Cisneros

Executive Name (Print)

City Manager

Executive Position

Signature

09/17/2017

Date





CA-NV AWWA Water Loss Technical Assistance Program

Wave 4 Water Audit Level 1 Validation Document

Audit Information:

Utility: Huntington Park

PWS ID: 1910049

System Type: Potable

Audit Period: Calendar 2016

Validation Date: 8/23/2017

Call Time: 2pm

Utility Representation: Christina Dixon (Public works analyst), Daniel Hernandez (Public Works Director), Iris Ramos

Sufficient Supporting Documents Provided: Yes

Validation Findings & Confirmation Statement:

Key Audit Metrics:

Data Validity Score: 63 Data Validity Band (Level): Band III (51-70)

ILI: 2.26

Real Loss: 24.79 (gal/conn/day)

Apparent Loss: 9.74 (gal/conn/day)

Non-Revenue Water as a Percentage of Operation Costs: 3.1%

Certification Statement by Validator:

7 and the California Water Code Section 10608.34. This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. oximes

Validator Information:

Water Audit Validator: Reinhard Sturm / Carolyn Prescott (support) Validator Qualifications: Contractor for CA-NV AWWA Water Loss



eline	connections/mile of pipe	* This performance indicator applies for systems with a low service connection density of less than 32 service connections/mile of pipeline	* This performance indicator applies for s
2.26	2.	? structure Leakage index (ILI) [CARL/UARL]:	
152.91 acre-feet/year	152.	From Above, Real Losses = Current Annual Real Losses (CARL):	
0.45]gallons/connection/day/psi	0.	Real Losses per service connection per day per psi pressure:	
N/A		Real Losses per length of main per day*:	Operational Elliciancy.
24.79 gallons/connection/day	24.	Real Losses per service connection per day:	
9.74 gallons/connection/day	9.	Apparent Losses per service connection per day:	
3.1% Real Losses valued at Variable Production Cost	3.	Non-revenue water as percent by cost of operating system:	T ili di Ciai.
5.4%	5.4	Non-revenue water as percent by volume of Water Supplied:	П. Э.
			Performance Indicators:
Return to Reporting Worksheet to change this assumption	\$83,806	Annual cost of Real Losses:	
	\$65,168	Annual cost of Apparent Losses:	
67.55 acre-ftyr	6/.	Poloable Annual Real Losses (UARL):	
212.987 acre-ft/yr	212.9	= Water Losses:	
152.905 acre-ft/yr	152.90	+ Real Losses:	
60.082 acre-ftlyr	60.0	Apparent Losses:	
			System Attributes:
	IS: 63 out of 100 ***	*** YOUR WATER AUDIT DATA VALIDITY SCORE IS: 63	
		Reporting Year: 2016 1/2016 - 12/2016	
		Water Audit Report for: City of Huntington Park	
American Water Works Association.	nce Indicators	System Attributes and Performance	
WAS v5.0		AWWA Free Water Audit Softwa	